

MATERIAL REACTION TO FIRE CLASSIFICATION
REPORT PREPARED IN COMPLIANCE WITH AMENDED 5 OF THE FRENCH HOME OFFICE
REGULATION DATED NOVEMBER 21ST, 2002 (OFFICIAL GAZETTE DATED DECEMBER 31, 2002)

Valid five years from issue date

CERTIFICATE N° 21-01822 L

And appendices of 6 pages

MATERIAL presented by: SMD Contracts Ltd.
Pittman Way,
Fulwood,
Preston,
England
PR2 9ZD

TRADE NAME: Brookland

BRIEF DESCRIPTION: Fabric 100% inherent fire resistant polyester
Measured surface weight: About 260 g/m²
Measured thickness: About 1.5 mm
Colours: Brown

TEST REPORT: N° 21-01822 E1V1 on June 04th 2021

TESTS: Electrical burner test
Flame persistence test
Dripping test.

CLASSIFICATION: **M 1**

CLASSIFICATION DURATION (article 5 of appendix 2) : unlimited unless otherwise specified

given the criteria resulting from the tests described in the enclosed test report.

The classification indicated does not mean that materials marketed comply with the test samples and must not be considered as a qualification certificate as defined by French law dated March 14, 2016.

N.B.: Only integral copies of this document may be made by photocopying the classification report and/or the classification report and enclosed test report.

Issued in Lyon, France, on June 04th 2021



Olivier PALLAS
Engineer Tests and Trials