



CLASSIFICATION TECHNICAL REPORT FOR CONSTRUCTION PRODUCTS

| | Report No.: | IN-02158/2018-C-E-3 |
|--------------------|-----------------------|---------------------|
| Applicant company: | SMD CONTRACTS LIMITED | |
| Address: | PITTMAN WAY, FULWOOD | |
| ZC – City: | PR2 92D - PRESTON | |
| County: | LANCASHIRE | |
| Country: | UNITED KINGDOM | |

DESCRIPTION OF THE PRESENTED MATERIAL

According to the information provided by the applicant:

| Reference or trade name of the product: | ELLIS | |
|---|--------------------------|--|
| Use or final disposition: | Courtains | |
| Composition: | Polyester | |
| Weight (g/linear meter) : | 400 | |
| Thickness (mm): | Information not provided | |
| Colour: | Information not provided | |

TECHNICAL DOCUMENTATION PRESENTED

Technical report **IN-02158/2018-E-3** issued by LEITAT on **January 11th, 2019**, which includes the following tests:

- TEXTILES AND TEXTILE PRODUCTS. BURNING BEHAVIOUR. CURTAINS AND DRAPES. DETAILED PROCEDURE TO DETERMINE THE IGNITABILITY OF VERTICALLY ORIENTED SPECIMENS (SMALL FLAME). Standard: UNE-EN 1101:1996/A1:2005
- TEXTILES AND TEXTILE PRODUCTS. BURNING BEHAVIOUR. CURTAINS AND DRAPES. MEASUREMENT OF FLAME SPREAD OF VERTICALLY ORIENTED SPECIMENS WITH LARGE IGNITION SOURCE. Standard: UNE-EN 13772:2011





CLASSIFICATION OF THE PRESENTED MATERIAL

According to the results obtained in the technical report number **IN-02158/2018-E-3**, performed on the basis of the aforementioned standards, and following the indications of **section 5** in **UNE-EN 13773:2003**, the material is classified as:

| STANDARD | CRITERIA | RESULTS | |
|--------------------------|-------------------------------------|---|--|
| | Ignition | Non-ignition | |
| UNE-EN 1101:1996/A1:2005 | Non-ignition | | |
| UNE-EN 1102:1996 | Not applicable | N.A. | |
| | First marking thread affected | _ | |
| UNE-EN 13772:2011 | Third marking thread affected | First marking thread not affected. No residues of the flame action. | |
| | Residues of the flame action appear | | |
| CLASSIFICATION | CLASS 1 | | |

Validated by:

Certifications Supervisor Josep Mª Pallarès

Terrassa, January 11th, 2019.