

CLASSIFICATION TECHNICAL REPORT FOR CONSTRUCTION PRODUCTS

Report No.:		IN-02158/2018-C-E-4
Applicant company:	SMD CONTRACTS LIMITED	
Address:	PITTMAN WAY, FULWOOD	
ZC – City:	PR2 92D - PRESTON	
County:	LANCASHIRE	
Country:	UNITED KINGDOM	

DESCRIPTION OF THE PRESENTED MATERIAL

According to the information provided by the applicant:

Reference or trade name of the product:	REMY
Use or final disposition:	Courtains
Composition:	Polyester
Weight (g/linear meter) :	400
Thickness (mm):	Information not provided
Colour:	Information not provided

TECHNICAL DOCUMENTATION PRESENTED

Technical report **IN-02158/2018-E-4** issued by LEITAT on **January 11th, 2019**, which includes the following tests:

- TEXTILES AND TEXTILE PRODUCTS. BURNING BEHAVIOUR. CURTAINS AND DRAPES. DETAILED PROCEDURE TO DETERMINE THE IGNITABILITY OF VERTICALLY ORIENTED SPECIMENS (SMALL FLAME).
Standard: UNE-EN 1101:1996/A1:2005
- TEXTILES AND TEXTILE PRODUCTS. BURNING BEHAVIOUR. CURTAINS AND DRAPES. MEASUREMENT OF FLAME SPREAD OF VERTICALLY ORIENTED SPECIMENS WITH LARGE IGNITION SOURCE.
Standard: UNE-EN 13772:2011

CLASSIFICATION OF THE PRESENTED MATERIAL

According to the results obtained in the technical report number **IN-02158/2018-E-4**, performed on the basis of the aforementioned standards, and following the indications of **section 5** in **UNE-EN 13773:2003**, the material is classified as:

STANDARD	CRITERIA	RESULTS
UNE-EN 1101:1996/A1:2005	Ignition	Non-ignition
	Non-ignition	
UNE-EN 1102:1996	Not applicable	N.A.
UNE-EN 13772:2011	First marking thread affected	First marking thread not affected. No residues of the flame action.
	Third marking thread affected	
	Residues of the flame action appear	
CLASSIFICATION	CLASS 1	

Validated by:



Certifications Supervisor
 Josep Mª Pallarès

Terrassa, January 11th, 2019.